

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 02/T7/AEE/2026

Dated: 17-06-2026

It is certified that an inspection team headed by D. Ravi Kiran

(Name of Officers with designation) from ASSISTANT EXECUTIVE ENGINEER PHED

inspected the Global Edge School, Plot No. 303 To 306, Sy No. 1052, KPHB Colony Hyd-50072

(Name & Address of the school) on (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. CEN/JNTU/26 dated 15-06-2026

of CENTRE FOR ENVIRONMENT JNTU (PHED Lab) certified that

the Global Edge School, Kukatpally (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One Year

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : PHED

Asst. Executive Engineer

O/o. Engineer-in-Chief

Public Health

A.O. Guards, Hyderabad,

To Global Edge School
Kukatpally, Hyd.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

For Global Edge School
M. Swathi Reddy
Authorised Signatory





CENTRE FOR ENVIRONMENT
UNIVERSITY COLLEGE OF ENGINEERING, SCIENCE AND TECHNOLOGY HYDERABAD
JAWAHARLAL NEHRU TECHNOLOGICAL UNIVERSITY HYDERABAD
Kukatpally, Hyderabad - 500 085, T.S. (India)

Dr.V.Himabindu, M.Tech, Ph.D.
Professor & Head

REPORT

Date 15/06/2026

Ref No: CEN/JNTU/26

Issued to:

M.s. GLOBAL EDGE SCHOOL
PLOT NO 303 TO 306, SY NO 1052
ROAD NO 4, KPHB COLONY
HYDERABAD 500072.

Sample Particulars: Water Sample, No. of Samples: 01

Water sample received from The Global Edge School, kukatpally, Hyderabad.

Only 1 sample for physicochemical analysis.

Sample Received Date: 05/06/2026

Test Required: water analysis as per IS 10500: 2012 Drinking water standards

PHYSICO-CHEMICAL ANALYSIS REPORT:

S No	Parameter	Waster sample result	Drinking Water Standards IS 10500: 2012	
			Desirable	Maximum
1	pH	6.75	6.5-8.5	-
2	EC(microsiemens/cm)	103	-	-
3	Color (Hazen Units)	1.0	5	15
4	Turbidity (NTU)	0.91	1	5
5	Total Dissolved Solids (mg/L)	68	500	2000
6	Chemical Oxygen Demand (COD) (mg/L)	ND	-	-
7	Total Hardness as CaCO ₃ (mg/L)	40	200	600
8	Alkalinity to Methyl Orange as CaCO ₃ (mg/L)	20	200	600
9	Calcium as Ca (mg/L)	8	75	200
10	Magnesium as Ca (mg/L)	4.8	30	100
11	Sodium as Na (mg/L)	16	-	-
12	Potassium as K (mg/L)	1.1	-	-
13	Chlorides as Cl (mg/L)	35	250	1000
14	Sulphates as SO ₄ (mg/L)	5	200	400
15	Nitrates as NO ₃ (mg/L)	1.4	45	-
16	Fluoride as F (mg/L)	1.15	0.5	1.5

Remarks: Sample is not drawn by us.

Note: 1 All Values are expressed as (mg/L) except pH, E.C, color and Turbidity

2 ND means non-detectable

Shruti Madan
Analyst

"Attested"

For Himabindu
(For Himabindu)

Asst. Executive Engineer
O/o. Engineer-in-Chief

Public Health
A.E. Gunder, Hyderabad

For Global Edge School

(V. Himabindu)

M. Swathi Reddy

HEAD

Authorised Signatory

Centre for Environment

University College of Engg. Science & Technology

JNTU University, Hyderabad

Kukatpally, Hyderabad - 500 085, T.S. (India)



CENTRE FOR ENVIRONMENT
UNIVERSITY COLLEGE OF ENGINEERING, SCIENCE AND TECHNOLOGY HYDERABAD
JAWAHARLAL NEHRU TECHNOLOGICAL UNIVERSITY HYDERABAD
Kukatpally, Hyderabad - 500 085, T.S. (India)

Dr.V.Himabindu, M.Tech, Ph.D.
Professor & Head

REPORT

Date 15/06/2026

Ref No.CEN/JNTU/26

Issued to:

M.s. GLOBAL EDGE SCHOOL
PLOT NO 303 TO 306, SY NO 1052
ROAD NO 4, KPHB COLONY
HYDERABAD 500072.

Sample Particulars: Water Sample, No. of Samples: 01

Water sample received from The Global Edge School, kukatpally, Hyderabad.

Only 1 sample for physicochemical analysis.

Sample Received Date: 05/06/2026

Test Required: water analysis as per IS 10500: 2012 Drinking water standards

PHYSICO-CHEMICAL ANALYSIS REPORT:

S No	Parameter	Waster sample result	Drinking Water Standards IS 10500: 2012	
			Desirable	Maximum
1	pH	6.75	6.5-8.5	-
2	EC(microsiemens/cm)	103	-	-
3	Color (Hazen Units)	1.0	5	15
4	Turbidity (NTU)	0.91	1	5
5	Total Dissolved Solids (mg/L)	68	500	2000
6	Chemical Oxygen Demand (COD) (mg/L)	ND	-	-
7	Total Hardness as CaCO ₃ (mg/L)	40	200	600
8	Alkalinity to Methyl Orange as CaCO ₃ (mg/L)	20	200	600
9	Calcium as Ca (mg/L)	8	75	200
10	Magnesium as Ca (mg/L)	4.8	30	100
11	Sodium as Na (mg/L)	16	-	-
12	Potassium as K (mg/L)	1.1	-	-
13	Chlorides as Cl (mg/L)	35	250	1000
14	Sulphates as SO ₄ (mg/L)	5	200	400
15	Nitrates as NO ₃ (mg/L)	1.4	45	-
16	Fluoride as F (mg/L)	1.15	0.5	1.5

Remarks: Sample is not drawn by us.

Note: 1. All Values are expressed as (mg/L) except pH, E.C, color and Turbidity

2. ND means non-detectable

Signature of Himabindu
Dr. V. Himabindu
Professor & Head

Signature of Kiran
(Kiran)
Asst. Executive Engineer
O/o. Engineer-in-Chief
Public Health
A.S. Grounds, Hyderabad.

For Global Edge School (V. Himabindu)

Signature of M. Swathi Reddy
M. Swathi Reddy

HEAD

Authorised Signatory

Centre for Environment
University College of Engg. Science & Technology
JNTU University, Hyderabad
Kukatpally, Hyderabad - 500 085, T.S. (India)